

The results (column J) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for copper is any result greater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not detected above the MDL.

REPORT TYPE CODE	CITY TOWN	ORG CODE	SCHOOL NAME	SCHOOL TYPE	LOCATION ID	SAMPLE LOCATION NAME	SAMPLE COMMENTS	ANALYTE NAME	RESULT	UNITS OF MEASUREMENT	METHOD DETECTION LIMIT	ANALYTICAL METHOD USED	ANALYSIS LAB	LAB SAMPLE ID	ANALYSIS COMMENTS	SAMPLER NAME	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	REPORT DATE
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	001F	Kitchen Kettle		COPPER	1.13	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 2		JP	10/5/2016	07:13:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	001F	Kitchen Kettle		LEAD	0.005	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 2		JP	10/5/2016	07:13:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	001P	Kitchen Kettle		COPPER	0.96	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 1		JP	10/5/2016	07:12:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	001P	Kitchen Kettle		LEAD	0.094	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 1		JP	10/5/2016	07:12:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	002F	Attached Fountain in Cafeteria		COPPER	0.037	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 4		JP	10/5/2016	07:20:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	002F	Attached Fountain in Cafeteria		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 4		JP	10/5/2016	07:20:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	002P	Attached Fountain in Cafeteria		COPPER	0.036	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 3		JP	10/5/2016	07:19:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	002P	Attached Fountain in Cafeteria		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 3		JP	10/5/2016	07:19:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	003F	Bubbler Outside Cafeteria		COPPER	0.24	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 6		JP	10/5/2016	07:24:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	003F	Bubbler Outside Cafeteria		LEAD	0.002	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 6		JP	10/5/2016	07:24:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	003P	Bubbler Outside Cafeteria		COPPER	0.57	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 5		JP	10/5/2016	07:23:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	003P	Bubbler Outside Cafeteria		LEAD	0.007	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 5		JP	10/5/2016	07:23:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	004F	Attached Fountain Outside Main Office		COPPER	0.041	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 8		JP	10/5/2016	07:27:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	004F	Attached Fountain Outside Main Office		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 8		JP	10/5/2016	07:27:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	004P	Attached Fountain Outside Main Office		COPPER	0.041	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 7		JP	10/5/2016	07:26:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	004P	Attached Fountain Outside Main Office		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 7		JP	10/5/2016	07:26:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	005F	Nurse's Office Sink		COPPER	0.3	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 10		JP	10/5/2016	07:28:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	005F	Nurse's Office Sink		LEAD	0.001	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 10		JP	10/5/2016	07:28:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	005P	Nurse's Office Sink		COPPER	0.46	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 9		JP	10/5/2016	07:27:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	005P	Nurse's Office Sink		LEAD	0.004	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 9		JP	10/5/2016	07:27:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	006F	Teacher's Room Sink		COPPER	0.31	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 12		JP	10/5/2016	07:31:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	006F	Teacher's Room Sink		LEAD	0.002	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 12		JP	10/5/2016	07:31:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	006P	Teacher's Room Sink		COPPER	0.46	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 11		JP	10/5/2016	07:30:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	006P	Teacher's Room Sink		LEAD	0.002	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 11		JP	10/5/2016	07:30:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	007F	Teacher's Room Coffee Maker		COPPER	0.2	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 14		JP	10/5/2016	07:32:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	007F	Teacher's Room Coffee Maker		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 14		JP	10/5/2016	07:32:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	007P	Teacher's Room Coffee Maker		COPPER	0.17	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 13		JP	10/5/2016	07:31:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	007P	Teacher's Room Coffee Maker		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 13		JP	10/5/2016	07:31:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	008F	Attached Fountain Outside Custodial Closet A		COPPER	0.031	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 15		JP	10/5/2016	07:34:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	008F	Attached Fountain Outside Custodial Closet A		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 15		JP	10/5/2016	07:34:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	008P	Attached Fountain Outside Custodial Closet A		COPPER	0.23	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 22		JP	10/5/2016	07:34:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	008P	Attached Fountain Outside Custodial Closet A		LEAD	0.001	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 22		JP	10/5/2016	07:34:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	010F	Boys Locker room Sink		COPPER	0.66	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 17		JP	10/5/2016	07:11:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	010F	Boys Locker room Sink		LEAD	0.01	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 17		JP	10/5/2016	07:11:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	010P	Boys Locker room Sink		COPPER	ND	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 16		JP	10/5/2016	07:11:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	010P	Boys Locker room Sink		LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 16		JP	10/5/2016	07:11:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	011F	Girls Locker Room Sink		COPPER	1.71	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 19		JP	10/5/2016	07:40:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	011F	Girls Locker Room Sink		LEAD	0.004	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 19		JP	10/5/2016	07:40:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	011P	Girls Locker Room Sink		COPPER	0.52	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 18		JP	10/5/2016	07:39:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	011P	Girls Locker Room Sink		LEAD	0.001	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 18		JP	10/5/2016	07:39:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	012F	Bubbler Outside Custodial Closet E		COPPER	0.64	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 21		JP	10/5/2016	07:44:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	012F	Bubbler Outside Custodial Closet E		LEAD	0.01	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 21		JP	10/5/2016	07:44:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	012P	Bubbler Outside Custodial Closet E		COPPER	0.7	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	171329 20		JP	10/5/2016	07:43:00	19-Oct-16
LCCA	Essex	06980020	Manchester Essex Regional: Essex Elementary	Public School	012P	Bubbler Outside Custodial Closet E		LEAD	0.003	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	171329 20		JP	10/5/2016	07:43:00	19-Oct-16